



NOTES

- DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.
- FINAL LOCATION OF MINIPILLARS & DUCTS TO BE AGREED WITH ESB SUPERVISOR PRIOR TO INSTALLATION.
- PROVIDE FOR ESB METER CABINET, INTERNAL METER & BRACKETS, SURGE PROTECTION & CABLE TO PUMPING STATION CONTROL PANEL.
- REFER TO ESB PUBLICATION ELECTRICAL SERVICES GUIDE BOOK FOR HOUSING SCHEMES FOR ALL INSTALLATION DETAILS.
- THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH THE NATIONAL CODE OF PRACTICE FOR CUSTOMER INTERFACE ISSUED BY ESB.
- THIS PROPOSAL IS SUBJECT TO APPROVAL FROM THE LOCAL AUTHORITY & PLANNING PERMISSION
- ALL PUBLIC LIGHTING COLUMNS MUST BE A MINIMUM OF 800mm AWAY FROM THE KERB EDGE.
- THERE SHALL NOT BE ANY MATURE TREE WITHIN 6M HORIZONTAL DISTANCE OF A 6M LIGHTING COLUMN OR WITH 8M HORIZONTAL DISTANCE OF AN 8M COLUMN.
- WHERE ACCESS TO LIGHTING COLUMNS IS OBSTRUCTED ETC A RAISE & LOWER MID-HINGED TYPE COLUMN SHOULD BE USED.
- THIS IS NOT AN APPROVED PUBLIC LIGHTING DESIGN DRAWING INFORMATION ONLY
- LOCATION OF LIGHTING PILLARS TO BE CONFIRMED ON RECEIPT OF ESB DESIGN DRAWING.
- THIS SCHEME WILL BE DIMMED TO 75% OUTPUT BETWEEN MID-NIGHT & 6AM. PHOTOCELLS SHALL HAVE 35/18LUX SWITCH ON/OFF LEVELS.
- DRAWING COMPLETED WITHOUT USE OF TAKING IN CHARGE DRAWING.
- ALL WORKS TO BE CARRIED OUT IN ACCORDANCE WITH LOCAL AUTHORITY PUBLIC LIGHTING GUIDELINES AND SPECIFICATION.

LEGEND

-  **COLUMN DETAILS A:**  
HEIGHT: 6m  
BRACKET LENGTH: :POST-TOP  
LANTERN TYPE: :14W LED  
MAKE & MODEL: :CU-PHOSCO-P950-28-P4A-730-CA0550-14W
-  **COLUMN DETAILS B:**  
HEIGHT: 66m  
BRACKET LENGTH: :POST-TOP  
LANTERN TYPE: :7W LED  
MAKE & MODEL: :CU-PHOSCO-P950-R3A-730-CA0250-7W
- NOTES:  
R&L = RAISE & LOWER MID-HINGED COLUMN TO BE USED IN ALL AREAS A HOIST IS INACCESSIBLE FOR MAINTENANCE
- C/W BAFFLE = COMPLETE WITH BAFFLE

D	FOR INFORMATION	RT	TMC	RMC	29/08/2025
C	FOR INFORMATION	RT	TMC	RMC	09/07/2025
B	FOR INFORMATION	RT	TMC	RMC	27/06/2025
A	FOR INFORMATION	RT	TMC	RMC	06/06/2025
ISSUE	DESCRIPTION	DRN	ORIG	APP	DATE

McElligott

CONSULTING ENGINEERS

Unit D4, Riverview Business Park, Nangor Road, Dublin 12  
tel: +353 (0)1 426 0099 email: info@mcelligott.ie web: www.mcelligott.ie

CLIENT

PROJECT

RATHMULLAN

TITLE

PUBLIC LIGHTING LAYOUT

SHEET	SCALE	PROJECT No.	DRAWING No.
A1	1:1000	25018	E040

